

PAT test Appliance Log tested by Stephen Heap. SkypePATtest. Date 01/11/2023
Varis, Reraig, Balmacara, IV40 8DH

AppNo	Location/Description	1,2,Ext	Visual inspect	Earth test ohms	Insula test Mohms	Pass/Fail
11559	Tall silver lamp		2 P		>20	Pass
11560	Router adapter		2 P			Pass Enclosed
11561	LG tv		2 P		>20	Pass
11562	AC adapter		2 P			Pass Enclosed
11563	Silver lamp		2 P		>20	Pass
11564	Extx6	Ext	P			Pass
11565	Extx6	Ext	P			Pass
11566	Tall brass lamp		2 P		>20	Pass
11567	Panasonic tv		2 P		7.88	Pass
11568	Hobbs microwave		1 P	0.04	>20	Pass
11569	Leakage radiation		P			Pass
11570	Silver toasterx4		1 P	0.02	>20	Pass
11571	Krupa coffee grinder		2 P		>20	Pass
11572	Bosch kettle		1 P	0.08	>20	Pass
11573	Beko dishwasher		1 P	0.08	>20	Pass
11574	Hotpoint washing machine		1 P	0.06	>20	Pass
11575	Bosch tumble dryer		1 P	0.04	>20	Pass
11576	Dimplex heater		2 P		>20	Pass
11577	Dimplex dehumidifier		1 P		>20	Pass Enclosed
11578	AC adapter		2 P			Pass Enclosed
11579	AC adapter		2 P			Pass Enclosed
11580	Vidal hairdryer		2 P			Pass Enclosed
11581	AC adapter for lamp		2 P			Pass Enclosed
11582	AC adapter for lamp		2 P			Pass Enclosed
11583	AC adapter for lamp		2 P			Pass Enclosed
11584	Babyliss hairdryer		2 P			Pass Enclosed
11585	Vidal hairdryer		2 P			Pass Enclosed
11586	AC adapter for lamp		2 P			Pass Enclosed
11587	Emergency light		2 P			Pass Enclosed
11588	Bosch fridge		1 P	0.07	>20	Pass

11589 BT adapter	2	P		Pass	Enclosed
11590 Numeric vacuum	1	P		Pass	Enclosed
11591 Steamjet	1	P		Pass	Enclosed
11592 Breville iron	1	P	0.01 >20	Pass	
11593 Extx2 reel	Ext	P	0.1 >20	Pass	
11594 AC adapter	2	P		Pass	Enclosed
11595 AC adapter	2	P		Pass	Enclosed
11596 AC adapter	2	P		Pass	Enclosed
11597 AC adapter	2	P		Pass	Enclosed
11598 AC adapter	2	P		Pass	Enclosed
11599 AC adapter	2	P		Pass	Enclosed
P50Powder fire extinguisher		P		Pass	

